



QUYX2.E244207
Process Control Equipment, Electrical - Component

[Page Bottom](#)

Process Control Equipment, Electrical - Component

[See General Information for Process Control Equipment, Electrical - Component](#)

PRECISION DIGITAL CORP
SUITE 5
89 OCTOBER HILL RD
HOLLISTON, MA 01746 USA

E244207

Temperature controllers, Models PD55*, PD54*, PD56*, PD57*.

* May be followed by a suffix 0 thru 9.

The acceptability of these devices with a specific end product is dependent upon the following conditions of acceptability:

1. The terminals provided on the PWB of the equipment have not been investigated for field connection. The acceptability of the connection to these terminals, including temperature and secureness, shall be determined in the ultimate application.
2. This component has been judged on the basis of a maximum altitude of 2000 m, Installation Category II, Pollution Degree 2 and the required spacings in The Standard for Process Control Equipment, UL 61010C-1, First Edition and CAN/CSA-C22.2 No. 1010.1-92, which would cover the component itself if submitted for Listing.
3. All power supply secondary output circuits are Limited Circuits (LIM or LC)
4. Transformer and Inductor employ an electrical insulation system designated Class A.
5. These controllers are intended for use in a cabinet. Only the front panel of this device has been investigated as an electrical enclosure. The front panel has not been investigated for its resistance to foreign objects of dust particles and moisture. When installed in the end-use equipment, the exposed terminals and ventilation openings on the rear portion of the controller shall be completely enclosed within the panel.
6. A switch or circuit-breaker acting as the disconnect device shall be included in the end-use equipment or the building installation.
7. A Temperature Test should be conducted in the end used equipment.
8. The front plate was not tested as a part of fire enclosure due to limited circuits. As a fire enclosure works the PWB (rated 94-V0) behind the front plate.
9. The device is suitable for use in a 50 C ambient.

Marking: Company name, model designation and the Recognized Component Mark  .
[Last Updated](#) on 2004-06-09

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.





QUYX8.E244207

Process Control Equipment, Electrical Certified for Canada - Component

[Page Bottom](#)

Process Control Equipment, Electrical Certified for Canada - Component

[See General Information for Process Control Equipment, Electrical Certified for Canada - Component](#)

PRECISION DIGITAL CORP

E244207

SUITE 5
89 OCTOBER HILL RD
HOLLISTON, MA 01746 USA

Temperature controllers, Models PD55*, PD54*, PD56*, PD57*.

* May be followed by a suffix 0 thru 9.

The acceptability of these devices with a specific end product is dependent upon the following conditions of acceptability:

1. The terminals provided on the PWB of the equipment have not been investigated for field connection. The acceptability of the connection to these terminals, including temperature and secureness, shall be determined in the ultimate application.
2. This component has been judged on the basis of a maximum altitude of 2000 m, Installation Category II, Pollution Degree 2 and the required spacings in The Standard for Process Control Equipment, UL 61010C-1, First Edition and CAN/CSA-C22.2 No. 1010.1-92, which would cover the component itself if submitted for Listing.
3. All power supply secondary output circuits are Limited Circuits (LIM or LC)
4. Transformer and Inductor employ an electrical insulation system designated Class A.
5. These controllers are intended for use in a cabinet. Only the front panel of this device has been investigated as an electrical enclosure. The front panel has not been investigated for its resistance to foreign objects of dust particles and moisture. When installed in the end-use equipment, the exposed terminals and ventilation openings on the rear portion of the controller shall be completely enclosed within the panel.
6. A switch or circuit-breaker acting as the disconnect device shall be included in the end-use equipment or the building installation.
7. A Temperature Test should be conducted in the end used equipment.
8. The front plate was not tested as a part of fire enclosure due to limited circuits. As a fire enclosure works the PWB (rated 94-V0) behind the front plate.
9. The device is suitable for use in a 50 C ambient.



Marking: Company name, model designation and the Recognized Component Mark for Canada

[Last Updated](#) on 2004-06-09

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2011 Underwriters Laboratories Inc.®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

